



材料暨工程實驗室-台中



Testing Laboratory
0292

試驗報告



報告編號：TB-25-00770

C-25-02032

頁數：1 OF 1

報告發行日期：114年02月20日

工程名稱：自測
承 包 商：-----
委託單位：松華實業股份有限公司
供料廠商：松華實業股份有限公司
樣品名稱：化粧粒片板
結構部位：(FB53400 18 mm M)
送驗人員：松華實業股份有限公司-黃福坤
取樣日期：114年02月13日
收件日期：114年02月14日
試驗日期：114年02月14日~114年02月20日

備 註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2.除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	方法偵測極限(MDL)	試驗方法
甲醛釋出量-最大值 (mg/L)	0.5	0.05	CNS 2215:2012
甲醛釋出量-平均值 (mg/L)	0.4	0.05	

註：1.試驗樣品厚度為 18.0 mm

- 試驗結果若低於方法偵測極限值(MDL)之測定值以"N.D."表示；
若高於方法偵測極限值(MDL)，但低於定量極限值(QDL)時，以"< 0.2"表示，
並括號註明其實測值，定量極限值(QDL)為 0.2 mg/L
- N.D. = Not Detected / 未檢出
- 樣品描述：粒片板
- 本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd, Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

TWE2148809

4005

試驗報告



報告編號：TB-25-07129

C-25-17458

頁數：1 OF 1

報告發行日期：114年11月06日

工程名稱：自測
 承包商：----
 委託單位：松華實業股份有限公司
 地址：台北市中山區松江路82號12樓
 供料廠商：----
 樣品名稱：化粧粒片板
 結構部位：53400月牙白(8 mm,F2,U型)
 加註項目：2100×2850×8 mm
 送驗人員：松華實業股份有限公司-黃福坤
 取樣日期：114年10月17日
 收件日期：114年10月29日
 試驗日期：114年10月29日~114年11月06日
 備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
 2.除非另有說明，此報告結果僅適用於收取之試驗件
 未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果			試驗方法
	測定項目	SAMPLE 1	SAMPLE 2	
防焰性	火源加熱時間(min)	2	2	CNS 11668:2008
	餘焰時間(sec)	0	0	
	餘燼時間(sec)	0	0	
	炭化面積(cm ²)	29	25	

- 註：1.試驗樣品厚度：SAMPLE 1為 8.0 mm；SAMPLE 2為 8.0 mm
 # 2.測試面為表面(素面)
 3.本試驗之樣品不在TAF認證範圍內，故無法出具TAF標誌之報告
 4.樣品描述：粒片板
 5.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

建築材料樣品試驗報告



報告編號：TB-25-06502

C-25-15747

頁數：1 OF 1

報告發行日期：114年11月04日

工程名稱：自測

承包商：----

委託單位：松華實業股份有限公司

供料廠商：----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年11月04日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
密度(g/cm ³)	0.73	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.1 mm

2.樣品描述：粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com.tw/terms-of-service> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <https://www.sgs.com.tw/terms-of-service>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

建築材料樣品試驗報告



報告編號：TB-25-06503

C-25-15748

頁數：1 OF 1

報告發行日期：114年11月04日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年11月04日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
含水率(%)	9	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.1 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com.tw/terms-of-service> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <https://www.sgs.com.tw/terms-of-service>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-台中



Testing Laboratory
0292

建築材料樣品試驗報告



報告編號：TB-25-06504

C-24-15749

頁數：1 OF 1

報告發行日期：114年10月28日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年10月28日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
抗彎強度 (N/mm ²)	21.0	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.1 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

謝淑敏
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com.tw/terms-of-service> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <https://www.sgs.com.tw/terms-of-service>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

建築材料樣品試驗報告



報告編號：TB-25-06505

C-25-15750

頁數：1 OF 1

報告發行日期：114年10月28日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年10月28日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
耐衝擊性 (W ₂ -300, 50 cm)	試體無放射狀龜裂、破壞及化粧層之剝離(平均凹陷直徑 10 mm)	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.0 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com.tw/terms-of-service> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <https://www.sgs.com.tw/terms-of-service>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-台中

建築材料樣品試驗報告



報告編號：TB-25-06506

C-25-15751

頁數：1 OF 1

報告發行日期：114年11月04日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年11月04日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2.除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
木螺釘保持力(N)	477	CNS 2215:2024

註：1.試驗樣品厚度為 18.3 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準


報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at: <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-台中

建築材料樣品試驗報告



報告編號：TB-25-06507

C-25-15752

頁數：1 OF 1

報告發行日期：114年11月04日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年11月04日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
內聚強度 (N/mm ²)	0.5	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.1 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

陳建發
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

建築材料樣品試驗報告



報告編號：TB-25-06508

C-25-15753

頁數：1 OF 1

報告發行日期：114年11月04日

工程名稱：自測
 承包商：-----
 委託單位：松華實業股份有限公司
 供料廠商：-----
 樣品名稱：化粧粒片板
 送驗人員：松華實業股份有限公司-黃福坤
 收件日期：114年09月25日
 試驗日期：114年09月25日~114年11月04日
 備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
平面抗拉強度 (N/mm ²)	0.5	CNS 2215:2024

註：1.試驗樣品平均厚度約為 8.0 mm

2.樣品描述：化粧粒片板

3.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-台中

建築材料樣品試驗報告



報告編號：TB-25-06510

C-25-15755

頁數：1 OF 1

報告發行日期：114年10月28日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年10月28日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2.除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

試驗結果：


試驗項目		試驗結果	試驗方法
耐汙染性	對紅色蠟筆之耐汙染性	污染用灰色標 4-5 號	CNS 2215:2024

註：1.樣品描述：化粧粒片板

2.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準


報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557
www.sgs.com.tw

Member of SGS Group


TWE4085085

4004
PENNY YH. 888



材料暨工程實驗室-台中

建築材料樣品試驗報告



報告編號：TB-25-06509

C-25-15754

頁數：1 OF 1

報告發行日期：114年10月28日

工程名稱：自測

承包商：-----

委託單位：松華實業股份有限公司

供料廠商：-----

樣品名稱：化粧粒片板

送驗人員：松華實業股份有限公司-黃福坤

收件日期：114年09月25日

試驗日期：114年09月25日~114年10月28日

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2.除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果	試驗方法
耐酸性(5%乙酸水溶液)	不變色	CNS 2215:2024
耐鹼性(1%碳酸鈉水溶液)	不變色	

註：1.樣品描述：化粧粒片板

2.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd, Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

TWE4085084



材料暨工程實驗室-高雄

試驗報告



報告編號: KV-25-09032

頁數: 1 OF 1

報告發行日期: 114 年 11 月 28 日

委託單位: 松華實業股份有限公司
送樣單位: 松華實業股份有限公司
公司統編: 04379292
公司地址: 台北市中山區松江路 82 號 12 樓
公司負責人: 楊惠信
身分證字號: A100552***
樣品名稱: 化粧粒片板
型號: 53400 月牙白(8 mm,F2,U 型)
主要材料或構件: 裝飾紙+粒片板+Melamine 樹脂硬化物
厚度: 8 mm
規格: 2100*2850*8 mm
送驗人員: 松華實業股份有限公司(黃福坤)
收件日期: 114 年 10 月 02 日
試驗日期: 114 年 10 月 02 日~114 年 11 月 28 日
備註:

1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2. 除非另有說明, 此報告結果僅適用於收取之試驗件未經本公司事先書面同意, 此報告不可部分複製
3. 本樣品由 SGS 材料暨工程實驗室-台中(申請書號碼: TB-25-06512 C-25-15757, 收件日期: 114 年 09 月 25 日)轉送至本實驗室執行本報告所示之試驗項目

試驗結果:

試驗項目		試驗方法	試驗結果
耐變褪色性 (WV type, 48 小時)	外觀	CNS 2215 : 2024	表面無裂隙、鼓脹等缺點
	色差 ΔE^*		1.64

- 註:
1. 試驗機型式: SUGA U48
 2. 濾鏡: 密閉式
 3. 使用光源: Ultraviolet Carbon Arc
 4. 測試條件: 黑板溫度: $(63 \pm 3)^{\circ}\text{C}$
相對濕度: $(30 \pm 5)\%\text{R.H.}$
測試週期: 100% 照光
 5. 色差條件: 波長: 360nm~780nm
光源: CIE illuminant D65
標準視角: 10°
 6. 樣品描述: 板材。
 7. 本實驗室執行試驗之地點同實驗室地址。

----- oOo -----

本報告若有提供規範值, 該規範值僅供參考, 合格之判定以委託單位實際要求為準

許明璋
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-台北



Testing Laboratory

2795

試驗報告



報告編號：HB-25-08673

C-25-31117

頁數：1 OF 1

報告發行日期：114年11月05日

委託單位：松華實業股份有限公司

公司統編：04379292

公司地址：台北市中山區松江路82號12樓

公司負責人：楊惠信

身分證字號：A100552***

樣品名稱：化粧粒片板

型號：53400 月牙白(8mm, F2, U型)

主要材料或構件：裝飾紙+粒片板+Melamine 樹脂硬化物

厚度：8mm

加註項目：2100*2850*8mm

送驗人員：松華實業股份有限公司(黃福坤)

收件日期：114年10月02日

試驗日期：114年10月02日 ~ 114年10月31日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

3. 本樣品由 SGS 材料暨工程實驗室-台中(申請書號碼：TB-25-06511 C-25-15756，
收件日期：114年09月25日)，轉送至本實驗室執行本報告所示之試驗項目。

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 2215 : 2024	12

註：1. 本試驗之樣品平均厚度約8.1mm。

2. 樣品描述：粒片板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
t (886-2) 2298-3355 f (886-2) 2299-7857

Member of SGS Group

TWB 9123712

www.sgs.tw



綠建材標章證書

綠建材標章證書字號：GBM0103241(續)

申請廠商：松華實業股份有限公司

申請人：楊惠信

廠商地址：臺北市中山區松江路82號12樓

產品名稱：化粧粒片板

產品型號：235340X 月牙白(25mm, F2, U型)、5940 碳墨灰(18mm, F2, U型)、
5330 雪花白(18mm, F2, U型)、235340X 月牙白(8mm, F2, U型)、
235340X 月牙白(18mm, F2, U型)、5600 淺銀灰(18mm, F2, U型)、
6270 時辰灰(18mm, F2, U型)、8315 灰雲岩(18mm, F2, U型)、
8316 雲金岩(18mm, F2, U型)、8915 維娜斯磐岩(18mm, F2, U型)、
8935 阿波羅磐岩(18mm, F2, U型)、9003 質樸櫟木紋(18mm, F2, U型)、
9005 北美鐵杉木紋(18mm, F2, U型)、9007 質樸黃櫟木紋(18mm, F2, U型)、
9011 淡晴灰櫟木紋(18mm, F2, U型)、9026 淳樸黃櫟木紋(18mm, F2, U型)、
9036 北美橙黃櫟木紋(18mm, F2, U型)、9038 咖啡胡桃木紋(18mm, F2, U型)、
9058 北歐白核桃木紋(18mm, F2, U型)、9065 歐洲灰褐胡桃木紋(18mm, F2, U型)、
9075 安貝格深櫟木紋(18mm, F2, 型)、9076 安貝格櫟木紋(18mm, F2, U型)、
9602 原切黑櫻桃木紋(18mm, F2, U型)、9642 原切白弦木紋(18mm, F2, U型)、
9692 歐洲白胡桃木紋(18mm, F2, U型)、9930 歐風可可櫟木紋(18mm, F2, U型)、
9940 煙燻咖啡櫟木紋(18mm, F2, U型)、9960 歐洲白栴木紋(18mm, F2, U型)

生產廠址：桃園市平鎮區湧豐里工業五路11、13、15號

有效期限：自113年1月22日至117年1月21日止

合格項目：健康綠建材(F2逸散)

試驗項目：甲醛(HCHO)逸散速率

總揮發性有機物質(TVOC)逸散速率

內政部 部長

林石昌

中華民國 112 年 12 月 28 日